


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009842A-R1
DATE: 03/24/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 05/04/2009

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.


The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics USA 8989 North Loop East Houston, TX 77029	Series "Nan Ya" 8' Out-Swing Hinged 3/4 Lite Fiberglass Patio Door Configuration: (1) Fixed Panel/(1) Active Panel/(1) Passive Panel Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass Max DLO: W-25.25" H-63.25" Frame: W-2686mm(105.75")H-2426mm(95.5") Panel: W-876mm(34.5") H-2370mm(93.32") STP: Pos+75.0 psf Neg-75.0 psf

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/L.S.2/NAFS-02 ASTM E330-02	HGD-R50 Design Pressure: +50/-50 psf

Product Tested By: Certified Testing Laboratories
 Report No: CTLA-1907W
 Expiration Date: January 31, 2013

Administrator's Signature: _____


NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 11870 Merchants Walk Suite 202
 Newport News, VA 23606
 TEL: (757) 594-8658
 FAX: (757) 594-8659