


# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI009842A-R1  
**DATE:** 03/24/2009  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya  
**CODE:** 661-1  
**REVISION DATE:** 05/04/2009

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.


The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics USA</b> <b>8989 North Loop East</b> <b>Houston, TX 77029</b>	<b>Series "Nan Ya" 8' Out-Swing</b> <b>Hinged 3/4 Lite Fiberglass Patio Door</b> Configuration: (1) Fixed Panel/(1) Active Panel/(1) Passive Panel Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass Max DLO: W-25.25" H-63.25" Frame: W-2686mm(105.75")H-2426mm(95.5") Panel: W-876mm(34.5") H-2370mm(93.32") STP: Pos+75.0 psf Neg-75.0 psf

SPECIFICATION	PRODUCT RATING
<b>AAMA/NWWDA 101/L.S.2/NAFS-02</b> <b>ASTM E330-02</b>	<b>HGD-R50</b> <b>Design Pressure: +50/-50 psf</b>

Product Tested By: Certified Testing Laboratories  
 Report No: CTLA-1907W  
 Expiration Date: **January 31, 2013**

Administrator's Signature: \_\_\_\_\_

  
**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
 11870 Merchants Walk Suite 202  
 Newport News, VA 23606  
 TEL: (757) 594-8658  
 FAX: (757) 594-8659