


# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006487  
DATE: 04/10/2006  
CERTIFICATION PROGRAM: Structural  
COMPANY: NanYa/Plastpro  
CODE: P-409-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>NanYa Plastics Corporation U.S.A</b> <b>8909 N. Loop E, Suite 800</b> <b>Houston, TX 77029</b>	<b>Series "9'0" x 8'0" Fiberglass</b> <b>Inswing Glazed Double Door"</b>  Configuration: XXX  Insulating Glass w/Laminate- Interior- 0.125" Annealed/0.090"PVB/0.125" Annealed/0.500" Air Space/Ext-0.125" Tempered Glass  All Specimens:  Frame:W-9'3" Panel:W-3'0" Opening:W-1'9"  H-8'0"          H-8'0"          H-6'7"

SPECIFICATION	PRODUCT RATING
<b>AAMA/NWDA 101/I.S.2-97</b> <b>ASTM E330-02</b> <b>AAMA 1302.5-76</b>	<b>HGD-LC25(w/water)</b> <b>Design Pressure: +50/-50 psf (w/o water)</b> <b>FER-Passed</b>

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-1420W-1(Structural/FER)  
Expiration Date: February 28, 2010

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**11870 Merchants Walk Suite 202**

**Newport News, VA 23606**

**TEL: (757) 594-8658**

**FAX: (757) 594-8659**