


# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI006486A  
**DATE:** 04/10/2006  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** NanYa/Plastpro  
**CODE:** P-409-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>NanYa Plastics Corporation U.S.A</b> <b>8909 N. Loop E, Suite 800</b> <b>Houston, TX 77029</b>	<b>Series "9'0" x 8'0" Fiberglass</b> <b>Outswing Glazed Double Door"</b>  Configuration: OXX  Insulating Glass w/Laminate- Interior- 0.125" Annealed/0.090" PVB/0.125" Annealed/0.500" Air Space/Ext-0.125" Tempered Glass  All Specimens: Frame: W-9'1" Panel: W-3'0" Opening: W-1'9"  H-8'0"      H-8'0"      H-6'7"

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-02/E1996-02</b>	<b>Design Pressure: +50/-50 psf</b> <b>Large Missile Impact Rated</b>

Product Tested By: Certified Testing Laboratories  
 Report No: CTLA-1508W-1(Impact)  
 Expiration Date: **February 28, 2010**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659